

XL 15i

MFR
DATE 9/2008

MOD.NO. 4TWX5030A100AA	VOLTS	200/230
SERIAL NO. XXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	17.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	20	20
MAX FUSE / BREAKER (HACR)	25	25
HFC - 410A	9 LBS. 03 OZ. OR	4.17 kg(SI)
10 °F DESIGN SUBCOOLING		

Climatuff DuraTuff Spine Fin Quick - Sess Weathertron

TRANE U.S. INC.

MANUFACTURER OF TRANE AND AMERICAN STANDARD

TYLER, TX 75707

ASSEMBLED IN USA



LISTED SECTION OF
HEAT PUMP

23MF OUTDOOR USE

COMPR. MOT.	11.1	RLA	200/230 V	63	LRA
O.D MOT.	2.80	FLA	200/230 V	1/3	HP
M.E.A. NO.	F. ID. 59Q				
DESIGN PSI - HIGH 480 LOW 480					



ARI Standard 210/240
Unitary Heat Pumps

BARCODE

CERTIFICATION APPLIES ONLY
WHEN THE COMPLETE SYSTEM
IS LISTED WITH ARI