

**TRANE**MFR DATE
11/2024

MOD. NO. 5TTR4042A1000AA	VOLTS	208 - 230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	19.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	30	30
R454B - A2L	5 LBS.	01 OZ.
	OR	2.29 kg(SI)
10°F/6°C	SC (TXV) OR SEE SH CHART IN LITERATURE SC CR 5kA rms	
	Climatuff DuraTuff Spine Fin Quick - Sess	

TRANETrane U.S. Inc.
TYLER, TX 75707

ASSEMBLED IN USA

CONDENSING UNIT
23MF

FOR OUTDOOR USE

COMPR. MOT. 14.1 RLA	208 - 230 V	109.0 LRA
O.D MOT. 1.05 FLA	200 - 230 V	1/8 HP
(PSI/MPA) MAX: 600/4.1 TEST: 450/3.1		F. ID. CT5


AHRI CERTIFIED™
www.ahridirectory.org
Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.

BARCODE



QR
CODE