

XB 1000

MFR
DATE 8/2004

MOD.NO. TTB024C100A2	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH	1 HZ 60
MINIMUM CIRCUIT AMPACITY	15.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	20	20
MAX FUSE / BREAKER (HACR)	25	25

HCFC - 22 3 LBS. **06** OZ. OR **1.53** kg(SI)
BAYFCCV 057A REQUIRED INDOORS FOR RATED PERFORMANCE

Climatuff DuraTuff Spine Fin Quick - Sess

**TRANE, A BUSINESS OF
AMERICAN STANDARD**



LISTED SECTION OF
CENTRAL COOLING
AIR CONDITIONER

TYLER, TX 75707 ASSEMBLED IN USA

23MF OUTDOOR USE

COMPR. MOT.	11.6	RLA	200/230	V	60	LRA
O.D MOT.	.98	FLA	200/230	V	1/6	HP
M.E.A. NO.	58 - 97E		F. ID. L36			

DESIGN PSI - HIGH 300 LOW 300



BARCODE

CERTIFICATION APPLIES
ONLY WHEN THE COMPLETE
SYSTEM IS LISTED WITH ARI