

**TRANE XV**

MFR DATE 5/2016

MOD.NO. 4TTV0036B1000BA

VOLTS 208/230

SERIAL NO. XXXXXXXXX

PH 1 HZ 60

MINIMUM CIRCUIT AMPACITY

18.0 AMPS

OVERCURRENT PROTECTIVE DEVICE

USA CANADA

MAX FUSE / BREAKER (HACR)

25 25

HFC - 410A 9 LBS. 06 OZ. OR 4.25 kg(SI)

10 +/- 3 °F DESIGN SUBCOOLING

Climatuff Duratuff Spine Fin Quick-Sess

TRANE

HEATING AND COOLING EQUIPMENT

A BUSINESS OF INGERSOLL RAND

TYLER, TX 75707 ASSEMBLED IN USA

Intertek 3059934

COMPR. MOT. 12.4 RLA 208/230 V 10.2 LRA

O.D MOT. 2.80 FLA 208/230 V 1/3 HP

DESIGN PSI - HIGH 480 LOW 480 F. ID. XXX

**ENERGY STAR****AHRI CERTIFIED™**
www.ahridirectory.orgUnitary Small AC
AHRI Standard 210/240

Certification applies only when the complete system is listed with AHRI.

C

BARCODE

Ingersoll Rand