

# Silver Series SI

MFR  
DATE 5/2010

MOD. NO. <b>4A7M306A1000AA</b>	VOLTS	<b>208/230</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH <b>1</b>	HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY	<b>35.0</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>60</b>	<b>60</b>
<b>HFC - 410A</b>	<b>4 LBS. 13</b>	<b>OZ. OR 2.18 kg(SI)</b>
SEE CHARGE LABEL		

## TRANE U.S INC.

MANUFACTURER OF TRANE AND AMERICAN STANDARD

TYLER, TX 75707 ASSEMBLED IN MEXICO



LISTED SECTION OF  
CENTRAL COOLING  
AIR CONDITIONER  
4000202 OUTDOOR USE

COMPR. MOT. <b>26.3</b>	RLA	<b>208/230</b>	V	<b>134</b>	LRA
O.D MOT. <b>1.7</b>	FLA	<b>200/230</b>	V	<b>1/3</b>	HP
M.E.A. NO.		F. ID. <b>CCP</b>			
DESIGN PSI - HIGH 480	LOW 480				



ARI Standard 210/240  
Unitary Heat Pumps

ARI Standard  
210/240 UAC

CERTIFICATION APPLIES ONLY  
WHEN THE COMPLETE  
SYSTEM IS LISTED WITH ARI

**B A R C O D E**