

# Allegiance 13

MFR  
DATE 8/2008

MOD.NO. <b>2A7A3048A1000AA</b>	VOLTS	<b>200/230</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH <b>1</b>	HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY	<b>25.0</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	<b>40</b>	<b>40</b>
MAX FUSE / BREAKER (HACR)	<b>40</b>	<b>40</b>

**HCFC - 22**      **8 LBS. 14 OZ.** OR      **4.03 kg(SI)**  
**10 °F DESIGN SUBCOOLING**

**Climatuff DuraTuff Spine Fin Quick - Sess**

## TRANE U.S INC.

MANUFACTURER OF TRANE AND AMERICAN STANDARD



LISTED SECTION OF  
CENTRAL COOLING  
AIR CONDITIONER

TYLER, TX 75707

**ASSEMBLED IN USA**

23MF OUTDOOR USE

COMPR. MOT.	<b>18.5</b> RLA	<b>200/230</b> V	<b>93.4</b> LRA
O.D MOT.	<b>1.4</b> FLA	<b>200/230</b> V	<b>1/6</b> HP
M.E.A. NO.	<b>154 - O6E</b>	F. ID. <b>XXX</b>	

DESIGN PSI - HIGH 300 LOW 300



**ARI Standard 210/240**  
**Unitary Heat Pumps**

# BARCODE

CERTIFICATION APPLIES  
ONLY WHEN THE COMPLETE  
SYSTEM IS LISTED WITH ARI