

XB 1000

MFR
DATE 07/2001

MOD.NO. **TTB042D100A0** VOLTS **200/230**
SERIAL NO. **XXXXXXXXXX** PH **1** HZ **60**
MINIMUM CIRCUIT AMPACITY **28.0** AMPS
OVERCURRENT PROTECTIVE DEVICE USA CANADA
RECOMMENDED FUSE / BREAKER (HACR) **40** **40**
MAX FUSE / BREAKER (HACR) **45** **45**
HCFC - 22 **4** LBS. **14** OZ. OR **2.21** kg(al)
BAYFCCV **077A** REQUIRED INDOORS FOR RATED PERFORMANCE

THE TRANE COMPANY
TYLER, TX 75711-9010 ASSEMBLED IN USA  OUTDOOR USE

COMPR. MOT. **21.9** RLA **208/230** V **127** LRA
O.D MOT. **1.40** FLA **200/230** V **1/4** HP
M.E.A. NO. **58 - 97E** F. ID. **LOB**
DESIGN PSI - HIGH 300 LOW 300

BARCODE