

XB 13

MFR
DATE 05/2008

MOD.NO. 4TTB3024A1000AA	VOLTS	200/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	12.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	20	20
MAX FUSE / BREAKER (HACR)	20	20
HFC - 410A	5 LBS. 10 OZ.	OR 2.55 kg(SI)
10 3 °F DESIGN SUBCOOLING		

Climatuff DuraTuff Spine Fin Quick - Sess Weathertron

TRANE U.S. INC.
MANUFACTURER OF TRANE AND AMERICAN STANDARD
TYLER, TX 75707 ASSEMBLED IN USA



LIMITED SECTION OF
CENTRAL COOLING
AIR CONDITIONER
23MF **OUTDOOR USE**

COMPR. MOT.	8.8	RLA	200/230 V	57.8	LRA
O.D MOT.	.70	FLA	200/230 V	1/8	HP
M.E.A. NO.			F. ID. XXX		
DESIGN PSI - HIGH 480 LOW 480					



ARI Standard 210/240
Unitary Heat Pumps
CERTIFICATION APPLIES ONLY
WHEN THE COMPLETE SYSTEM
IS LABELED WITH ARI

BARCODE