

**TRANE XR**MFR
DATE 8/2021

MOD. NO. 4TWR4018G1000AC	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	12.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	20	20
HFC - 410A	5 LBS. 12 OZ. OR	2.61 kg(SI)
10 °F SC (TXV) OR SEE SH CHART IN LITERATURE		SCCR 5kA rms
Climatuff DuraTuff Spine Fin Quick-Sess Weathertron		

TRANETrane U.S Inc.
TYLER, TX 75707**ASSEMBLED IN USA**CONDENSING UNIT
SA11679

OUTDOOR USE

COMPR. MOT.	9.0	RLA	208/230 V	56	LRA
O.D MOT.	0.54	FLA	200/230 V	1/12	HP
DESIGN PSI - HIGH 480 LOW 480			F. ID. T7S		

AHRI CERTIFIED™
www.ahridirectory.orgUnitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE****QR
CODE**