

**TRANE XR**

MFR DATE 10/2020

MOD. NO. 4TTR4060L1000BA	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60

MINIMUM CIRCUIT AMPACITY	27.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	45	45
HFC - 410A	7 LBS. 10 OZ. OR	3.46 kg(SI)

10 °F SC (TXV) OR SEE SH CHART IN LITERATURE **SCCR 5kA rm 8**
 Climatuff Duratuff Spine Fin Quick-Sess

TRANECONDENSING UNIT
SA11679Trane U.S. Inc.
TYLER, TX 75707

ASSEMBLED IN USA

OUTDOOR USE

COMPR. MOT. 20.8	RLA	208/230 V	127.1	LRA
O.D MOT. 0.93	FLA	200/230 V	1/5	HP
DESIGN PSI - HIGH 480	LOW 480	F. ID. XXX		

AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
 AHRI Standard 210/240

Certification applies only when the complete system
 is listed with AHRI.

C

BARCODE**QR
CODE**