

**TRANE XR**MFR DATE **6/2020**

MOD.NO. 4TTR3018H1000NB	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	12.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	20	20
HFC - 410A	4 LBS. 08	0Z. OR 1.98 kg(SI)
10 °F SC (TXV) OR SEE SH CHART IN LITERATURE		SCCR 5ka rms
Climatuff DuraTuff Spine Fin Quick-Sess		

TRANECONDENSING UNIT
SA11679Trane U.S. Inc.
TYLER, TX 75707

ASSEMBLED IN USA



OUTDOOR USE

COMPR. MOT. 9.0	RLA	208/230	V	48.0	LRA
O.D. MOT. 0.60	FLA	200/230	V	1/15	HP
DESIGN PSI - HIGH 480	LOW 480	F. ID. G1R			

Install Prohibited In Southeast and Southwest.


AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE****QR
CODE**