

**TRANE XR**MFR  
DATE **2/2019**

MOD.NO. <b>4TWR4018G1000AB</b>	VOLTS	<b>208/230</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH 1	HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY	<b>12.0</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>20</b>	<b>20</b>
<b>HFC - 410A</b>	<b>6 LBS. 01 OZ. OR</b>	<b>2.75 kg(SI)</b>
<b>10 +/- 3 °F</b> DESIGN SUBCOOLING		<b>SCCR 5kA rms</b>

Climatuff Duratuff Spine Fin Quick-Sess Weathertron

**TRANE**HEATING AND COOLING  
EQUIPMENTA BUSINESS OF INGERSOLL RAND  
TYLER, TX 75707 ASSEMBLED IN USA**Intertek**

3059934

COMPR. MOT.	<b>9.0</b>	RLA	<b>208/230 V</b>	<b>56</b>	LRA
O.D MOT.	<b>0.54</b>	FLA	<b>200/230 V</b>	<b>1/12</b>	HP
DESIGN PSI - HIGH 480 LOW 480			F. ID. <b>E7S</b>		

**AHRI** CERTIFIED™  
[www.ahridirectory.org](http://www.ahridirectory.org)Unitary Small AC  
AHRI Standard 210/240Certification applies only when the complete system  
is listed with AHRI.**BARCODE** **Ingersoll-Rand**