

AIR CONDITIONER

MFR
DATE 4/2012

MOD.NO. 4TTA3048D3000CA	VOLTS	208/230
SERIAL NO. XXXXXXXXX	PH 3	HZ 60
MINIMUM CIRCUIT AMPACITY	18.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	30	30
HFC - 410A	6 LBS. 13 OZ. OR	3.09 kg(SI)
10 +/- 3 °F DESIGN SUBCOOLING		
Climatuff DuraTuff Spine Fin Quick - Sess		

TRANE U.S INC.

MANUFACTURER OF TRANE AND AMERICAN STANDARD
TYLER, TX 75707 ASSEMBLED IN USA



LISTED SECTION OF
CENTRAL COOLING
AIR CONDITIONER
3059934 OUTDOOR USE

COMPR. MOT.	16.7	RLA	200/230	V	83	LRA
O.D MOT.	0.64	FLA	200/230	V	1/5	HP
M.E.A. NO.	F. ID. XXX					
DESIGN PSI - HIGH 480 LOW 480						

AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240

Certification applies only when the complete system
is listed with AHRI.

C

BARCODE