

# XR 13

MFR  
DATE 11/2006

|                               |               |                |
|-------------------------------|---------------|----------------|
| MOD.NO. 2TWR3024A1000AA       | VOLTS         | 200/230        |
| SERIAL NO. XXXXXXXXX          | PH 1          | HZ 60          |
| MINIMUM CIRCUIT AMPACITY      | 12.0          | AMPS           |
| OVERCURRENT PROTECTIVE DEVICE | USA           | CANADA         |
| MIN FUSE / BREAKER (HACR)     | 20            | 20             |
| MAX FUSE / BREAKER (HACR)     | 20            | 20             |
| HCFC - 22                     | 5 LBS. 11 OZ. | OR 2.58 kg(SI) |
| 12 °F DESIGN SUBCOOLING       |               |                |

Climatuff DuraTuff Spine Fin Quick - Sess Weathertron

AMERICAN STANDARD INC.  
MANUFACTURER OF TRANE AND AMERICAN STANDARD  
TYLER, TX 75707 ASSEMBLED IN USA



LISTED SECTION OF  
HEAT PUMP

23MF OUTDOOR USE

|                               |           |         |           |      |     |
|-------------------------------|-----------|---------|-----------|------|-----|
| COMPR. MOT.                   | 8.7       | RLA     | 200/230 V | 57.8 | LRA |
| O.D MOT.                      | 1.30      | FLAPPLY | 200/230 V | 1/4  | HP  |
| M.E.A. NO.                    | 200 - 06E |         | F. ID.    | 32M  |     |
| DESIGN PSI - HIGH 300 LOW 300 |           |         |           |      |     |



ARI Standard 210/240  
Unitary Heat Pumps

ARI Standard  
210/240 UAC

CERTIFICATION APPLIES ONLY  
WHEN THE COMPLETE SYSTEM  
IS LISTED WITH ARI

BARCODE