

# ***XE 1200***

MFR  
DATE **08/96**

MOD.NO. **TTP036C100A2** VOLTS **200/230**

SERIAL NO. **XXXXXXXXXX** PH **1** HZ **60**

MINIMUM CIRCUIT AMPACITY **23.0** AMPS

OVERCURRENT PROTECTIVE DEVICE USA CANADA

RECOMMENDED FUSE / BREAKER (HACR) **40** **40**

MAX FUSE / BREAKER (HACR) **40** **40**

HCFC - 22 **8** LBS. **12** OZ. OR **3.97** kg(si)

BAYFCCV **077A** REQUIRED INDOORS FOR RATED PERFORMANCE

THE TRANE COMPANY  
TYLER, TX 75711 - 9010 ASSEMBLED IN USA

OUTDOOR USE

COMPR. MOT. **17.0** RLA **200/230** V **91** LRA

O.D MOT. **1.90** FLA **200/230** V **1/4** HP

M.E.A. NO. **179-93E**

DESIGN PSI - HIGH 300 LOW 300

F. ID. **P17**