

AIR CONDITIONER

MFR
DATE 8/2020

MOD. NO. A4AC4060A1000AA	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH	1 HZ 60
MINIMUM CIRCUIT AMPACITY	31.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	50	50
HFC - 410A	7 LBS.	10 OZ. OR 3.46 kg(SI)

10 °F SC (TXV) OR SEE SH CHART IN LITERATURE SCCR 5KA r m s
Climatuff Duratuff Spine Fin Quick-Sess

RunTru

Trane U.S Inc.
TYLER, TX 75707

ASSEMBLED IN USA



CONDENSING UNIT
SA11679

OUTDOOR USE

COMPR. MOT.	23.7	RLA	208/230 V	152.5	LRA
O.D MOT.	0.93	FLA	200/230 V	1/5	HP
DESIGN PSI - HIGH 480 LOW 480			F. ID. TER		

AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240

Certification applies only when the complete system
is listed with AHRI.

BARCODE

QR
CODE