

**TRANE XR**MFR
DATE 9/2021

MOD. NO. 4TTR402L1000AA	VOLTS	208/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	22	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	35	35
HFC - 410A	6 LBS. 02 OZ. OR	2.78 kg(SI)

12 °F SC (TXV) OR SEE SH CHART IN LITERATURE

Climatuff Duratuff Spine Fin Quick-Sess

TRANETrane U.S Inc.
TYLER, TX 75707**ASSEMBLED IN USA**CONDENSING UNIT
SA11679

OUTDOOR USE

COMPR. MOT. 16.7	RLA	208/230 V	109	LRA
O.D MOT. 0.93	FLA	200/230 V	1/5	HP
DESIGN PSI - HIGH 480	LOW 480	F. ID. XXX		

AHRI CERTIFIED™www.ahridirectory.orgUnitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE****QR
CODE**