TRANE **XV**

MFR DATE 7/2016

MOD.NO. **4TWV0048A1000BA** VOLTS **208/230**
SERIAL NO. **XXXXXXXXX** PH **1** HZ **60**

MINIMUM CIRCUIT AMPACITY **29.0** AMPS
OVERCURRENT PROTECTIVE DEVICE USA CANADA
MAX FUSE / BREAKER (HACR) **45** **45**
HFC - 410A **10** LBS. **12** OZ. OR **4.88** kg(SI)

10 +/- 3 °F DESIGN SUBCOOLING
Climatuff Duratuff Spine Fin Quick-Sess

TRANE

A BUSINESS OF INGERSOLL RAND
TYLER, TX 75707 ASSEMBLED IN USA

HEATING AND COOLING EQUIPMENT

Intertek 3059934

COMPR. MOT.	**21.1**	RLA	**208/230**	V	**12.0**	LRA
O.D MOT.	**2.80**	FLA	**208/230**	V	**1/3**	HP
DESIGN PSI - HIGH 480 LOW 480			F. ID. **XXX**			

WILAD HVAC SUPPLY

AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240

Certification applies only when the complete system is listed with AHRI.

BARCODE

Ingersoll-Rand