

AIR CONDITIONER

MFR
DATE 08/2001

MOD.NO. TTA030C400A1	VOLTS	460
SERIAL NO. XXXXXXXXXX	PH 3	HZ 60
MINIMUM CIRCUIT AMPACITY	7.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
RECOMMENDED FUSE / BREAKER (HACR)	15	15
MAX FUSE / BREAKER (HACR)	15	15
HCFC - 22 4 LBS. 02 OZ.	OR	1.87 kg(si)
BAYFCCV 067A	REQUIRED INDOORS FOR RATED PERFORMANCE	

THE TRANE COMPANY

TYLER, TX 75711 - 9010 ASSEMBLED IN USA



OUTDOOR USE

COMPR. MOT. 5.0 RLA	460 V	38	LRA
O.D MOT. .80 FLA	460 V	1/4	HP
M.E.A. NO. 56 - 92E	F. ID. A0B		
DESIGN PSI - HIGH 300 LOW 300	BARCODE		