

# American Standard

MFR  
DATE 9/2010

MOD.NO. <b>4A6C3030A4000BA</b>	VOLTS	<b>460</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH <b>3</b>	HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY	<b>5.0</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>15</b>	<b>15</b>
<b>HFC - 410A</b> <b>6</b> LBS. <b>01</b> OZ.	OR	<b>2.75</b> kg(SI)
<b>9 °F</b> DESIGN SUBCOOLING		

**Climatuff DuraTuff Spine Fin Quick - Sess**

TRANE U.S. INC.  
MANUFACTURER OF TRANE AND AMERICAN STANDARD  
TYLER, TX 75707 ASSEMBLED IN USA



LIMITED SECTION OF  
CENTRAL COOLING  
AIR CONDITIONER

**OUTDOOR USE**

COMPR. MOT.	<b>3.9</b> RLA	<b>460</b>	V	<b>28.0</b>	LRA
O.D MOT.	<b>.40</b> FLA	<b>460</b>	V	<b>1/8</b>	HP
M.E.A. NO.		F. ID.	<b>XXX</b>		
DESIGN PSI - HIGH 480 LOW 480					



ARI Standard 210/240  
Unitary Heat Pumps

## BARCODE

CERTIFICATION APPLIES ONLY  
WHEN THE COMPLETE SYSTEM  
IS LABELED WITH ARI