

XB 13

MFR
DATE 1/2008

MOD.NO. 2TTB3060A1000AA	VOLTS	200/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	33.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	50	50
MAX FUSE / BREAKER (HACR)	50	50
HCFC - 22	8 LBS. 11 OZ.	OR 3.94 kg(SI)

10 °F DESIGN SUBCOOLING

Climatuff DuraTuff Spine Fin Quick - Sess

TRANE U.S. INC.
MANUFACTURER OF TRANE AND AMERICAN STANDARD
TYLER, TX 75707 ASSEMBLED IN USA



LIMITED SECTION OF
CENTRAL COOLING
AIR CONDITIONER

23MF OUTDOOR USE

COMPR. MOT.	25.0	RLA	200/230 V	148	LRA
O.D MOT.	1.30	FLA	200/230 V	1/4	HP
M.E.A. NO.	154 - 06E		F. ID. 19N		

DESIGN PSI - HIGH 300 LOW 300



ARI Standard 210/240
Unitary Heat Pumps

ARI Standard
210/240 UAC

CERTIFICATION APPLIES ONLY
WHEN THE COMPLETE SYSTEM
IS LISTED WITH ARI

BARCODE