



TRANE XR

MFR 6/2015
DATE

MOD. NO. 4TWR4030D1000AA

VOLTS 208/230

SERIAL NO. XXXXXXXXX

PH 1 HZ 60

MINIMUM CIRCUIT AMPACITY

15.0 AMPS

OVERCURRENT PROTECTIVE DEVICE

USA CANADA

MAX FUSE / BREAKER (HACR)

25 25

HFC - 410A 8 LBS. 02 OZ. OR 3.68 kg(SI)

10 +/- 3 °F DESIGN SUBCOOLING

Climatuff DuraTuff Spine Fin Quick-Sess Weathertron

TRANE



HEATING AND COOLING
EQUIPMENT

A BUSINESS OF INGERSOLL RAND

TYLER, TX 75707 ASSEMBLED IN USA

Intertek

3059934

COMPR. MOT. 11.3 RLA 208/230 V 68.2 LRA

O.D MOT. 1.20 FLA 200/230 V 1/5 HP

DESIGN PSI - HIGH 480 LOW 480 F. ID. W8Q

AHRI

CERTIFIED™

www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240

Certification applies only when the complete system
is listed with AHRI.

BARCODE

Ingersoll-Rand