

**TRANE**

MFR DATE

**3/2025**

MOD.NO. <b>5TTA4048A4000AA</b>	VOLTS	<b>460</b>
SERIAL NO. <b>XXXXXXXX</b>	PH ~	<b>3 HZ 60</b>
MINIMUM CIRCUIT AMPACITY	<b>8.6</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>15</b>	<b>15</b>
<b>R454B - A2L</b>	<b>6 LBS. 10 OZ.</b>	OR <b>2.15 kg(SI)</b>
<b>10°F/6°C</b>	SC (TXV) OR SEE SH CHART IN LITERATURE SC CR 5kA rms	
<b>Climatuff DuraTuff Spine Fin Quick - Sess</b>		

**TRANE**Trane U.S. Inc.  
TYLER, TX 75707**ASSEMBLED IN USA**CONDENSING UNIT  
23MF

FOR OUTDOOR USE

<b>COMPR. MOT. 6.4 RLA</b>	<b>460</b>	<b>V</b>	<b>50 LRA</b>
<b>O.D MOT. 0.6 FLA</b>	<b>460</b>	<b>V</b>	<b>1/5 HP</b>
(PSI/MPA) MAX: 600/4.1 TEST: 450/3.1		F. ID. <b>GD5</b>	


**AHRI CERTIFIED™**  
[www.ahridirectory.org](http://www.ahridirectory.org)
Unitary Small AC  
AHRI Standard 210/240Certification applies only when the complete system  
is listed with AHRI.

**BARCODE**



**QR  
CODE**