

**TRANE XV**MFR DATE
9/2023

MOD.NO. 4TWR6036N1000AA	VOLTS	208 - 230
SERIAL NO. XXXXXXXXX	PH ~ 1	HZ 60
MINIMUM CIRCUIT AMPACITY	37.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	50	50
HFC - 410A	13LBS. 02 OZ.	OR 5.95 kg(SI)
10°F	SC (TXV) OR SEE SH CHART IN LITERATURE SCCR 5kA rms	
Climatuff Duratuff Spine Fin Quick - Sess Weathertron		

TRANETrane U.S Inc.
TYLER, TX 75707CONDENSING UNIT
23MF**ASSEMBLED IN USA**

FOR OUTDOOR USE

COMPR. MOT. 27.5 RLA	208 - 230 V	12.0	LRA
O.D MOT. 2.80 FLA	208 - 230 V	1/3	HP
DESIGN PSI - HIGH 480 LOW 480	F. ID. XXX		


AHRI CERTIFIED™
www.ahridirectory.org
Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE****QR
CODE**