

Allegiance 20

MFR
DATE 4/2009

MOD. NO. 4A7Z0060A1000AA	VOLTS 200/230
SERIAL NO. XXXXXXXXXX	PH 1 HZ 60
MINIMUM CIRCUIT AMPACITY	31.0 AMPS
OVERCURRENT PROTECTIVE DEVICE	USA CANADA
MIN FUSE / BREAKER (HACR)	50 50
MAX FUSE / BREAKER (HACR)	50 50
HCFC - 410A 13 LBS. 15 OZ. OR 6.32 kg(SI)	

* *

Duration DuraBase Spine Fin Easy - Sess

TRANE U.S INC.
MANUFACTURER OF TRANE AND AMERICAN STANDARD
TYLER, TX 75707



LISTED SECTION OF
CENTRAL COOLING
AIR CONDITIONER
3059934 OUTDOOR USE

ASSEMBLED IN USA

COMPR. MOT. 22.8 RLA	200/230 V	128.7 LRA
O.D MOT. 2.80 FLA	200/230 V	1/3 HP
M.E.A. NO.	F. ID. 15Y	

DESIGN PSI - HIGH 480 LOW 480



ARI Standard 210/240
Unitary Heat Pumps

CERTIFICATION APPLIES
ONLY WHEN THE COMPLETE
SYSTEM IS LISTED WITH ARI

BARCODE