

**TRANE XLi**

MFR DATE 3/2023

MOD.NO. 4TTX7024E1000AA	VOLTS	<b>208/230</b>
SERIAL NO. XXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	<b>18.4</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>20</b>	<b>20</b>
HFC - 410A	9 LBS. 04 OZ. OR	<b>4.20</b> kg(SI)
9 °F SC (TXV) OR SEE SH CHART IN LITERATURE		SCCR 5kA rms
<i>Climatuff DuraTuff Spine Fin Quick-Sess</i>		

**TRANE**CONDENSING UNIT  
SA11679Trane U.S. Inc.  
TYLER, TX 75707

ASSEMBLED IN USA



OUTDOOR USE

COMPR. MOT.	<b>10.2</b>	RLA	<b>208/230</b> V	<b>55.2</b>	LRA
O.D. MOT.	<b>0.64</b>	FLA	<b>208/230</b> V	<b>1/8</b>	HP
DESIGN PSI - HIGH 480 LOW 480			F. ID. <b>EMT</b>		

**AHRI CERTIFIED™**  
[www.ahridirectory.org](http://www.ahridirectory.org)Unitary Small AC  
AHRI Standard 210/240Certification applies only when the complete system  
is listed with AHRI.**BARCODE****QR  
CODE**