

**TRANE XLi**MFR
DATE 2/2019

MOD.NO. 4TTX6024J1000BA	VOLTS	208/230
SERIAL NO. XXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	13.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	20	20
HFC - 410A	5 LBS. 03 OZ. OR	2.35 kg(SI)
8 +/- 3 °F DESIGN SUBCOOLING		SCCR 5kA rms

Climatuff Duratuff Spine Fin Quick-Sess

TRANEHEATING AND COOLING
EQUIPMENT

A BUSINESS OF INGERSOLL RAND

TYLER, TX 75707 ASSEMBLED IN USA

Intertek

3059934

COMPR. MOT.	10.1	RLA	208/230 V	52	LRA
O.D MOT.	0.64	FLA	200/230 V	1/8	HP
DESIGN PSI - HIGH	480	LOW	480	F. ID.	XXX


AHRI CERTIFIED™
www.ahridirectory.org
Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI**BARCODE** **Ingersoll-Rand**