



TRANE XR

MFR DATE 7/2015

| | | |
|-------------------------------|------------------|-------------|
| MOD. NO. 4TTR4030L1000AA | VOLTS | 208/230 |
| SERIAL NO. XXXXXXXXX | PH 1 | HZ 60 |
| MINIMUM CIRCUIT AMPACITY | 17.0 | AMPS |
| OVERCURRENT PROTECTIVE DEVICE | USA | CANADA |
| MAX FUSE / BREAKER (HACR) | 25 | 25 |
| HFC - 410A | 5 LBS. 04 OZ. OR | 2.37 kg(SI) |
| 10 +/- 3 °F DESIGN SUBCOOLING | | |

Climatuff DuraTuff Spine Fin Quick-Sess Weathertron

TRANE



HEATING AND COOLING EQUIPMENT

A BUSINESS OF INGERSOLL RAND
TYLER, TX 75707 ASSEMBLED IN USA

Intertek 3059934

| | | | | | | |
|-------------------|------|-----|---------|-----|------|-----|
| COMPR. MOT. | 12.8 | RLA | 208/230 | V | 68.0 | LRA |
| O.D MOT. | 0.77 | FLA | 200/230 | V | 1/6 | HP |
| DESIGN PSI - HIGH | 480 | | LOW | 480 | | |
| | | | F. ID. | WLP | | |

Install Prohibited in Southwest.



BARCODE

