

**TRANE XR**MFR 8/2017
DATEMOD. NO. **4TTR4018L1000AB**
SERIAL NO. **XXXXXXXXXX**VOLTS **208/230**
PH **1** HZ **60**MINIMUM CIRCUIT AMPACITY **12.0** AMPS
OVERCURRENT PROTECTIVE DEVICE USA CANADA
MAX FUSE / BREAKER (HACR) **20** **20**
HFC - 410A **4** LBS. **08** OZ. OR **1.98** kg(SI)**10 +/- 3 °F** DESIGN SUBCOOLING
Climatuff Duratuff Spine Fin Quick-Sess**TRANE**HEATING AND COOLING
EQUIPMENTA BUSINESS OF INGERSOLL RAND
TYLER, TX 75707 ASSEMBLED IN USA**Intertek**COMPR. MOT. **9.0** RLA **208/230** V **48.0** LRA
O.D MOT. **0.90** FLA **200/230** V **1/15** HP
DESIGN PSI - HIGH 480 LOW 480 F. ID. **FAR****AHRI****CERTIFIED™**
www.ahridirectory.orgUnitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE** **Ingersoll-Rand**