

# AIR CONDITIONER

MFR  
DATE 8/2020

MOD. NO. <b>A4AC4060A1000AA</b>	VOLTS	<b>208/230</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH	<b>1</b> HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY		<b>31.0</b> AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	<b>50</b>	<b>50</b>
<b>HFC - 410A</b>	<b>7</b> LBS.	<b>10</b> OZ. OR <b>3.46</b> kg(SI)

**10** °F SC (TXV) OR SEE SH CHART IN LITERATURE SCCR 5KA r m s  
Climatuff Duratuff Spine Fin Quick-Sess

RunTru

Trane U.S Inc.  
TYLER, TX 75707

ASSEMBLED IN USA



CONDENSING UNIT  
SA11679

OUTDOOR USE

COMPR. MOT.	<b>23.7</b> RLA	<b>208/230</b> V	<b>152.5</b> LRA
O.D MOT.	<b>0.93</b> FLA	<b>200/230</b> V	<b>1/5</b> HP
DESIGN PSI - HIGH 480 LOW 480		F. ID. <b>TER</b>	



BARCODE

QR  
CODE