

XE 1000

MFR
DATE **06/99**

MOD.NO. TWR030C100A4	VOLTS	200/230
SERIAL NO. XXXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	18.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	30	30
MAX FUSE / BREAKER (HACR)	30	30
HCFC - 22 5 LBS. 01 OZ.	OR	2.30 kg(si)
BAYFCCV 069A	REQUIRED INDOORS FOR RATED PERFORMANCE	

THE TRANE COMPANY
TYLER, TX 75711-9010 ASSEMBLED IN USA



OUTDOOR USE

COMPR. MOT. 13.0 RLA	200/230 V	79 LRA
O.D MOT. 1.50 FLA	200/230 V	1/4 HP
M.E.A. NO. 55-92E		
DESIGN PSI - HIGH 300 LOW 300		

F. ID. **T34**