

**TRANE XR**MFR DATE **2/2016**

MOD.NO. 4TTR3018H1000NA	VOLTS	208/230
SERIAL NO. XXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	12.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	20	20
HFC - 410A	4 LBS. 08 OZ. OR	1.98 kg(SI)

10 +/- 3 °F DESIGN SUBCOOLING

Climatuff DuraTuff Spine Fin Quick - Sess

TRANE

HEATING AND COOLING EQUIPMENT

A BUSINESS OF INGERSOLL RAND

TYLER, TX 75707

ASSEMBLED IN USA

Intertek

3059934

COMPR. MOT. 9.0	RLA	208/230 V	63.0	LRA
O.D. MOT. 0.60	FLA	200/230 V	1/15	HP
DESIGN PSI - HIGH 480	LOW 480	F. ID. ZJP		

Install Prohibited in Southeast and Southwest.



AHRI CERTIFIED™
www.ahridirectory.org

Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.**BARCODE**