

**TRANE**

MFR DATE

6/2025

MOD.NO. 5TWA4048A4000AA	VOLTS	460
SERIAL NO. XXXXXXXXXX	PH ~	3 HZ 60
MINIMUM CIRCUIT AMPACITY	9.4	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MAX FUSE / BREAKER (HACR)	15	15
R454B - A2L	10LBS.	04 OZ. OR 4.65 kg(SI)
10°F/6°C SC (TXV) OR SEE SH CHART IN LITERATURE SCCR 5kA rms		
Climatuff DuraTuff Spine Fin Quick - Sess Weathertron		

TRANETrane U.S. Inc.
TYLER, TX 75707

ASSEMBLED IN USA

**US LISTED**CONDENSING UNIT
23MF

FOR OUTDOOR USE

COMPR. MOT. 6.4 RLA	460	V	50 LRA
O.D MOT. 1.4 FLA	460	V	1/3 HP
(PSI/MPA) MAX: 600/4.1 TEST: 450/3.1		F. ID. E36	


AHRI CERTIFIED™
www.ahridirectory.org
Unitary Small AC
AHRI Standard 210/240Certification applies only when the complete system
is listed with AHRI.

BARCODE



**QR
CODE**