

# XL 19i

MFR  
DATE 7/2008

MOD.NO. 2TWZ9048C1000AA	VOLTS	200/230
SERIAL NO. XXXXXXXXX	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	25.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	40	40
MAX FUSE / BREAKER (HACR)	40	40
HCFC - 22	15 LBS. 08 OZ.	OR 7.03 kg(SI)

Climatuff DuraTuff Spine Fin Quick - Sess Weathertron

TRANE U.S. INC.  
MANUFACTURER OF TRANE AND AMERICAN STANDARD  
TYLER, TX 75707

UL US  
LIMITED SECTION OF  
HEAT PUMP  
ASSEMBLED IN USA  
23MF OUTDOOR USE

COMPR. MOT.	17.6	RLA	200/230V	107	LRA
O.D MOT.	2.80	FLA	200/230V	1/3	HP
M.E.A. NO.		F. ID.	XXX		
DESIGN PSI - HIGH	300	LOW	300		



ARI Standard 210/240  
Unitary Heat Pumps  
CERTIFICATION APPLIES ONLY  
WHEN THE COMPLETE SYSTEM  
IS LABELED WITH ARI

## BARCODE