

# **XB 13**

**MFR**  
**DATE 12/2008**

MOD.NO. <b>4TTB3030A1000AA</b>	VOLTS	<b>200/230</b>
SERIAL NO. <b>XXXXXXXXXX</b>	PH <b>1</b>	HZ <b>60</b>
MINIMUM CIRCUIT AMPACITY	<b>12.0</b>	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	<b>20</b>	<b>20</b>
MAX FUSE / BREAKER (HACR)	<b>25</b>	<b>25</b>
<b>HFC - 410A</b>	<b>5 LBS. 11 OZ.</b>	OR <b>2.58 kg(SI)</b>
<b>10 3 °F DESIGN SUBCOOLING</b>		

**Climatuff DuraTuff Spine Fin Quick - Sess**

TRANE U.S. INC.  
MANUFACTURER OF TRANE AND AMERICAN STANDARD  
TYLER, TX 75707 ASSEMBLED IN USA



LIMITED SECTION OF  
CENTRAL COOLING  
AIR CONDITIONER

23MF **OUTDOOR USE**

COMPR. MOT.	<b>11.1</b>	RLA	<b>200/230 V</b>	<b>83</b>	LRA
O.D MOT.	<b>.70</b>	FLA	<b>200/230 V</b>	<b>1/8</b>	HP
M.E.A. NO.			F. ID. <b>12P</b>		
DESIGN PSI - HIGH 480 LOW 480					



ARI Standard 210/240  
Unitary Heat Pumps

CERTIFICATION APPLIES ONLY  
WHEN THE COMPLETE SYSTEM  
IS LABELED WITH ARI

## **BARCODE**